

Westwood Public Schools
Hanlon Elementary School
Building Project

School Building Committee

08.25.2020



Agenda

- **Decision Points Overview**
- **Geothermal Test Well update**
- **Overview: Life Cycle Cost Analysis (LCCA)**
- **Rainwater Cistern - Irrigation**
- **Recommendation from Sustainability Subcommittee**

Decision Points - Overview

1. **Priority: 20% above new energy code to achieve 2% points from MSBA**
2. **Heating/Cooling System options:**
 - **Baseline: Natural Gas**
 - **Tier 1: Water Source Heat Pump with supplemental electric boiler**
 - **Tier 2: Ground Source Heat Pump (Geothermal) :**
 - **Tier 3: Ground Source Heat Pump (Geothermal):
with supplemental electric boiler, less wells**
3. **100% A/C vs. partial A/C and dehumidification ventilation**
4. **Rainwater Cistern-Irrigation**

Geothermal Test Well – Update

Test Well Program and Geologic Conditions:

- Test Well completed with no issues, faster than expected (600' in one day)
- Vibration levels measured were low
- Granite encountered 10' below grade
- Water yield: approx. 5-10 GPM

Implications for Design:

- Rock has higher conductivity than soil: Granite = good
- Once thermo-conductivity test is complete (next week), well will be covered



Geothermal Test Well – Possible Locations

Implications for Design:

- Approximately 70 wells are anticipated at 25' apart.
- 3-4 months for drilling (with two drill rigs)
- Can be done at beginning, during or end of construction (non-critical path item)



Life Cycle Cost Analysis – Summary

EUI

Baseline	System	Gross Capital Investment*	Annual Elec. Cons. (kWh)	Annual Gas Cons. (MBTU)	Annual Electric Cost	Annual Gas Cost	Combined Utility Cost	Annual Utility \$/s.f.	Annual kBTU/s.f. (EUI)	Annual Maint. Cost	20 Year Exterior Equipment Replacement Cost	Combined Annual Expense	Combined Expense Savings**	Total Life-Cycle Savings***	Discounted Payback (Years)****
Code Baseline Natural Gas	1. Hot water coil heating/chilled water coil cooling VAV AHU system with energy recovery and terminal VAV boxes with hot water reheat coils 2. Code-efficient gas-fired non-condensing boiler plant 3. High-efficiency (code) water-cooled chiller plant with cooling tower	\$7,065,144	542,150	1,784.8	\$108,430	\$22,489	\$130,919	\$1.16	32.1	\$132,704	\$1,469,500	\$263,623	-	-	-

Option	System	Gross Capital Investment*	Annual Elec. Cons. (kWh)	Annual Gas Cons. (MBTU)	Annual Electric Cost	Annual Gas Cost	Combined Utility Cost	Annual Utility \$/s.f.	Annual kBTU/s.f. (EUI)	Annual Maint. Cost	20 Year Exterior Equipment Replacement Cost	Combined Annual Expense	Combined Expense Savings**	Total Life-Cycle Savings***	Discounted Payback (Years)****
Base Design Natural Gas	1. Dehumidification displacement ventilation diffusers with radiant heating panels 2. Gas-fired heating/dx cooling VAV ventilating units with energy recovery with terminal VAV boxes with CO2 controls 3. High efficiency gas-fired condensing boiler plant	\$6,026,583	511,760	1,561.7	\$102,353	\$19,678	\$122,031	\$1.08	29.2	\$130,279	\$919,850	\$252,310	\$11,313	\$1,856,606	Instant *****
21.6% energy savings above Code Baseline															
Tier 1 WSHP Elct Blr	1. Dehumidification displacement ventilation diffusers with radiant heating panels 2. Hot water coil heating/chilled water cooling VAV ventilating units with energy recovery with terminal VAV boxes with CO2 controls 3. High efficiency water-cooled chiller plant with dry cooler 4. Supplemental electric boiler plant	\$7,666,934	887,380	0.0	\$175,476	\$0	\$175,476	\$1.55	26.8	\$122,079	\$330,000	\$297,555	-\$33,932	-\$685,229	Not Reached *****
Tier 2 GSHP	1. Dehumidification displacement diffusers with radiant heating panels 2. Hot water coil heating/chilled water cooling VAV ventilating units with energy recovery with terminal VAV boxes with CO2 controls 3. Geothermal wells with high-efficiency water-to-water source heat pump chillers	\$10,917,434	667,000	0.0	\$133,400	\$0	\$133,400	\$1.18	20.1	\$121,079	\$0	\$254,479	\$9,144	-\$2,307,572	Not Reached *****
Tier 3 GSHP Elct Blr	1. Dehumidification displacement diffusers with radiant heating panels 2. Hot water coil heating/chilled water cooling VAV ventilating units with energy recovery with terminal VAV boxes with CO2 controls 3. Geothermal wells with high-efficiency water-to-water source heat pump chillers 4. Supplemental electric boiler plant	\$10,459,048	754,620	0.0	\$150,923	\$0	\$150,923	\$1.33	22.8	\$122,079	\$0	\$273,002	-\$9,379	-\$2,396,360	Not Reached *****

Sustainability Subcommittee Recommends Fossil Fuel Free Approach:



- Additional Capital Cost= worthwhile investment
- Consistent with Westwood's Commitment to Sustainability and Resiliency
- Life of the Building Decision
- Statewide Direction Fossil Fuel Free
- Opportunity for Net Zero Energy
- Reduction in Global Greenhouse Gas Emissions

Tier 1 vs. Tier 2 – Heating/Cooling Systems

Tier 1: Municipal Water Source Heat Pump System

Pros

- Aligns with Westwood Resiliency and Sustainability Comprehensive Draft Plan
- Lower upfront cost

Cons

- Less energy efficient than Tier 2 system resulting in:
 - May require increased electrical service capacity
 - More solar energy required for NZE
 - Increased generator size required
- Need supplemental electric boiler due to heat rejection
- More mechanical equipment visible exterior than Tier 2
- **Higher HVAC sound levels at building exterior vs. Tier 2**
- More maintenance -moving parts, vs. Tier 2

Tier 2: Geothermal Source Heat Pump System

Pros

- Aligns with Westwood Resiliency and Sustainability Comprehensive Draft Plan
- More energy efficient than Tier 1 system resulting in:
 - Likely decrease in electrical service capacity vs Tier 1
 - Less solar energy required for NZE
 - Smaller generator size required
- Less mechanical equipment visible at building exterior
- Lower HVAC sound levels at building exterior vs. Tier 1
- Less annual maintenance: fewer moving parts vs. Tier 1

Cons

- Higher upfront cost

Rainwater Cistern – Irrigation: \$140k

- Utilizing native plants and water efficient irrigation methods can minimize the need for excessive water
- Harvesting rain water: effective and educational for a small area
- The heaviest rain events: spring
vs.
Most need for irrigation is during July/August. **The tank can never be large enough to meet the peak demands**
- Supplemental water necessary to meet the irrigation needs
- Cistern/tank water needs treatment to potable water standards. **Increased annual operating and maintenance costs**
- Will not achieve payback
- **Potential for increased cost due to possible ledge**

40,000 gallon tank

10'-12' below grade

Annual water savings: 595,000 gallons

15% of water demand met




Recommendation from Sustainability Subcommittee

- 1. Priority: 20% above new energy code to achieve 2% points from MSBA.... \$83.3 M
- 2. Heating/Cooling System options:
 - ~~Baseline: Natural Gas~~ ~~Included~~
 - ~~Tier 1: Water Source Heat Pump with supplemental electric boiler: Add \$1.5 M~~
 - Tier 2: Ground Source Heat Pump (Geothermal) :** **Add \$3.5 M**
 - OR**
 - Tier 3: Ground Source Heat Pump (Geothermal):** **Add \$3.5 M**
with supplemental electric boiler, less wells
- 3. 100% A/C vs. partial A/C and dehumidification ventilation:..... \$ 1.3 M
- 4. Rainwater Cistern-Irrigation: \$ 0.2 M

Revised Project Cost Estimate **\$88.1 M Total**

Shuttleworth and Hanlon School Properties




TOTAL SHUTTLEWORTH: 37.5 acres

Area 1: approx. 9.5 acres School
Area 2: approx. 11.25 acres PV array
Area 3: approx. 16.75 acres remaining
Total: 37.5

Existing Hanlon School property: approx. 8.6 acres

Total all areas: approx. 45.6 acres





Questions?