

# LEED and NZE Review HVAC System Follow-Up



Hanlon Elementary School  
Westwood, MA

October 22, 2020



**Garcia, Galuska & DeSousa**  
Consulting Engineers Inc.

375 Faunce Corner Road, Suite D, Dartmouth, MA 02747-1258



**The Green Engineer**  
Sustainable Design Consulting

# AGENDA

- LEED Checklist and Sustainability Update
- Net Zero Energy (NZE)
- HVAC Systems – Follow up

# Westwood Hanlon LEED



## LEED v4 for BD+C: Schools Project Checklist

Y	?	N		
1	0	0	<b>Integrative Process</b>	<b>1</b>
1			Credit Integrative Process	1
Y	?	N		
3	6	6	<b>Location and Transportation</b>	<b>15</b>
		N	Credit LEED for Neighborhood Development Location	15
1			Credit Sensitive Land Protection	1
1	1		Credit High Priority Site	2
1	1	3	Credit <u>Surrounding Density and Diverse Uses (RP@4)</u>	5
	2	2	Credit <u>Access to Quality Transit (RP@1)</u>	4
		1	Credit Bicycle Facilities	1
	1		Credit Reduced Parking Footprint	1
	1		Credit Green Vehicles	1
Y	?	N		
4	7	1	<b>Sustainable Sites</b>	<b>12</b>
Y			Prereq Construction Activity Pollution Prevention	Required
Y			Prereq Environmental Site Assessment	Required
1			Credit Site Assessment	1
	2		Credit <u>Site Development - Protect or Restore Habitat (RP@2)</u>	2
1			Credit Open Space	1
	3		Credit Rainwater Management	3
	2		Credit Heat Island Reduction	2
1			Credit Light Pollution Reduction	1
		1	Credit Site Master Plan	1
1			Credit Joint Use of Facilities	1
Y	?	N		
3	9	0	<b>Water Efficiency</b>	<b>12</b>
Y			Prereq Outdoor Water Use Reduction	Required
Y			Prereq Indoor Water Use Reduction	Required
Y			Prereq Building-Level Water Metering	Required
1	1		Credit Outdoor Water Use Reduction	2
	2	5	Credit Indoor Water Use Reduction	7
	2		Credit Cooling Tower Water Use	2
	1		Credit Water Metering	1
Y	?	N		
22	9	0	<b>Energy and Atmosphere</b>	<b>31</b>
Y			Prereq Fundamental Commissioning and Verification	Required
Y			Prereq Minimum Energy Performance	Required
Y			Prereq Building-Level Energy Metering	Required
Y			Prereq Fundamental Refrigerant Management	Required
	5	1	Credit Enhanced Commissioning	6
	14	2	Credit <u>Optimize Energy Performance (RP@8)</u>	16
		1	Credit Advanced Energy Metering	1
	2		Credit Demand Response	2
	3		Credit <u>Renewable Energy Production (RP@2)</u>	3
	1		Credit Enhanced Refrigerant Management	1
	2		Credit Green Power and Carbon Offsets	2

Project Name: Westwood Hanlon ES

Date: 10.7.20

Y	?	N		
3	8	2	<b>Materials and Resources</b>	<b>13</b>
Y			Prereq Storage and Collection of Recyclables	Required
Y			Prereq Construction and Demolition Waste Management Planning	Required
	5		Credit <u>Building Life-Cycle Impact Reduction (RP@2)</u>	5
1	1		Credit BPDO - Environmental Product Declarations	2
	1	1	Credit Building Product Disclosure and Optimization - Sourcing of Raw Materials	2
1		1	Credit Building Product Disclosure and Optimization - Material Ingredients	2
1	1		Credit Construction and Demolition Waste Management	2
Y	?	N		
6	10	0	<b>Indoor Environmental Quality</b>	<b>16</b>
Y			Prereq Minimum Indoor Air Quality Performance	Required
Y			Prereq Environmental Tobacco Smoke Control	Required
Y			Prereq Minimum Acoustic Performance	Required
	2		Credit Enhanced Indoor Air Quality Strategies	2
	2	1	Credit Low-Emitting Materials	3
1			Credit Construction Indoor Air Quality Management Plan	1
	2		Credit Indoor Air Quality Assessment	2
	1		Credit Thermal Comfort	1
1	1		Credit Interior Lighting	2
	3		Credit Daylight	3
	1		Credit Quality Views	1
	1		Credit Acoustic Performance	1
Y	?	N		
4	2	0	<b>Innovation</b>	<b>6</b>
1			Credit Innovation: Resonable Purchasing - Lamps	1
1			Credit Innovation: Economic and GHG Analysis of Mechanical Systems	1
1			Credit Innovation: Pilot - Integrative Analysis of Building Materials	1
	1		Credit Innovation: TBD	1
	1		Credit Innovation: TBD	1
1			Credit LEED Accredited Professional	1
Y	?	N		
2	2	0	<b>Regional Priority (max of 4 points) Credit Names have been underlined</b>	<b>4</b>
		X	Credit <u>Surrounding Density and Diverse Uses (RP@4)</u>	
	1		Credit <u>Access to Quality Transit (RP@1)</u>	1
	1		Credit <u>Site Development - Protect or Restore Habitat (RP@2)</u>	1
1			Credit <u>Optimize Energy Performance (RP@8)</u>	1
1			Credit <u>Renewable Energy Production (RP@2)</u>	1
	X		Credit <u>Building Life-Cycle Impact Reduction (RP@2)</u>	

48 53 9 TOTAL Possible Points: 110

Certified: 40 to 49 points, Silver: 50 to 59 points, Gold: 60 to 79 points, Platinum: 80 to 110

48 53 9 TOTAL

Certified: 40 to 49 points

The Green Engineer  
Sustainable Design Consulting

# Westwood Hanlon REC Primer

- RECs put the “Renewable” in Renewable Electricity
- REC = Renewable Energy Certificate are a mechanism to track the production of clean energy and represent the social and environmental benefit of the production of 1 MWh. These can be sold separately from the power itself.
- Electrons produced by a solar panel are no different than electrons produced by a coal-fired power plant or any other electricity generating technology.
- Renewable electricity generators, therefore, produce two distinct market commodities:
  - 1) electricity and
  - 2) RECs.
  - These commodities can be used and/or sold separately or together. The REC instrument embodies the environmental attributes of the underlying electricity generated from a renewable resource.
- Since Ameresco is selling the SRECs generated (or retained as part of SMART program) at Shuttleworth the power delivered to Westwood can no longer be formally considered “green”.
- So, to formally claim NZE the town would have to rebuy RECs for the amount of renewable energy claimed.

Sources: <https://www.epa.gov/sites/production/files/2017-09/documents/gpp-guidelines-for-making-solar-claims.pdf>

## What is a REC?

A **REC** is a tradeable, market-based instrument that represents the legal property rights to the “renewable-ness”— or all non-power attributes— of renewable electricity generation.


A REC is issued for every megawatt-hour (MWh) of electricity generated and delivered to the electric grid from a renewable energy resource.

The REC owner has exclusive rights to make claims about “using” or “being powered with” the renewable electricity associated with that REC and thus avoid the double counting of the same generation attributes by another party.

RECs are the instrument used to substantiate the use of renewable electricity for both voluntary and compliance purposes. For voluntary purposes, consumers such as residential households and businesses use RECs to demonstrate claims of using renewable electricity. For compliance purposes, RECs are used to track that utilities are meeting their state-imposed mandates.

# Westwood Hanlon REC Arbitrage

## What is a Renewable Energy Certificate?





# Westwood Hanlon REC Arbitrage

- REC arbitrage (also referred to as a REC swap) is a procurement strategy used by electricity consumers to simultaneously meet two objectives:
  - 1) decrease the cost of their renewable electricity use and
  - 2) substantiate renewable electricity use and carbon footprint reduction claims.
- The strategy is used by consumers installing self-financed renewable electricity projects or consumers who purchase renewable electricity directly from a renewable electricity project, such as through a power purchase agreement (PPA).
- A prerequisite of REC arbitrage is that there are differences in REC prices.
- State renewable portfolio standard (RPS) policies are a major demand driver for RECs and consequently impact REC prices.

**Cost of Buying RECs:** Sample to repurchase RECs to offset 100% of electricity use

Tier 2		Tier 3	
Electrical		Electrical	
kWh/yr	693,790	kWh/yr	766,320
REC rate* (\$/kWh)	\$ 0.0012	REC rate* (\$/kWh)	\$ 0.0012
Replacement \$/yr	\$ 832.55	Replacement \$/yr	\$ 919.58

Sources: <https://www.epa.gov/sites/production/files/2017-09/documents/gpp-guidelines-for-making-solar-claims.pdf>

# What are Net Zero Energy Buildings?

- Currently, practitioners and policy-makers do not have a consensus-based definition of net zero energy, near net zero energy, or energy positive buildings.
- The most commonly referenced definition was developed by the U.S.DOE in 2015 (see Table 1).
- Although the U.S. Department of Energy's (DOE) and the Massachusetts DOER Zero Net Energy Buildings Task Force's definitions emphasize the use of renewable energy on-site, many stakeholders view off-site renewables as essential to achieving net zero energy given limited roof and open space.
- Emissions-based targets can be more feasible for existing facilities that have already made significant energy efficiency investments and/or have a mix of on- and off-site renewable power.

**TABLE 1: Net Zero, Near Net Zero, and Energy Positive Definitions**

NET ZERO ENERGY	NEAR NET ZERO ENERGY	ENERGY POSITIVE
<b>An energy efficient building which generates on-site renewable energy greater than the total amount consumed on-site.<sup>18</sup></b> —U.S. Department of Energy	<b>Buildings that may be designed to achieve one or more net zero definitions (e.g. net zero energy or emissions), but may not achieve a net zero energy in operations every year.<sup>19</sup></b> —National Renewable Energy Laboratory	<b>Produce more energy from renewables (on- or off-site) than needed for energy consumption.<sup>22</sup></b> —Boston Planning and Development Agency
<b>Note:</b> Some "net zero" definitions allow off-site renewable energy to be purchased to offset on-site use. The U.S. DOE refers to this as Renewable Energy Certificate—Zero Energy Building (REC-ZEB). Similarly, some definitions consider "net zero carbon" or "net zero emissions" rather than energy use for their performance standard. These standards typically allow for off-site generation.	<b>Note:</b> There is no official federal definition of near net zero energy.	<b>Note:</b> In practice, some facilities that designate themselves energy positive do not use all building energy loads in their calculations. <sup>23</sup>

# Westwood Hanlon NZE Classification

**National Renewable Energy Laboratory NZE Classifications:** In general, a project can claim to be NZE with either on or off-site PV (assuming RECs are retained or repurchased). They would be considered different “classes” or approaches, but all would be NZE.

## **NZE Classifications:**

Class A – renewables within building footprint – e.g. PV on the roof

Class B – renewables on building site – e.g. parking canopies

Class C – off site renewables – e.g. community solar (where SRECs are retained)

Class D – RECs or renewable energy purchased – e.g. buy RECs and carbon offsets



# Westwood Hanlon Energy Performance Requirements

**MSBA Requirement:** The Project is subject to the MSBA requirements of Project Advisory 41 - Sustainable Building Design Policy for Green Schools. Since the Project is seeking an additional 2% reimbursement from the MSBA, the building will need to demonstrate at least a 20% reduction compared to the base energy code (IECC 2018/ASHRAE 90.1-2016 with MA Amendments). Compliance for this requirement is enforced through the point total under the LEED for Schools v4 EAc Optimize Energy Performance credit which uses ASHRAE 90.1-2010 as the baseline. Our understanding is that projects seeking the additional reimbursement will be required to show at least 14 points (35% reduction compared to 90.1-2010) under the EAc Optimize Energy Performance credit to show equivalency.

**Stretch Energy Code Requirement:** Since Westwood is a Stretch Code Community, the Project will be subject to ASHRAE 90.1-2013 with updated Massachusetts Amendments and must demonstrate at least a 10% EUI reduction, either in site or source energy, to demonstrate energy code compliance.

Source:

[https://www.massschoolbuildings.org/building/advisories/Project\\_Advisory\\_41](https://www.massschoolbuildings.org/building/advisories/Project_Advisory_41)

<https://www.mass.gov/doc/780-cmr-ninth-edition-chapter-13-energy-efficiency-amendments-as-of-272020/download>

# Ground Source Heat Pump – Alternative Energy Portfolio Standard

- Additional source of financial benefit for Town.
- The Alternative Energy Portfolio Standard (APS) provides an incentive to Massachusetts homeowners and businesses to install eligible alternative energy systems that lower greenhouse gas emissions and increase energy efficiency across the Commonwealth.
- The APS is a market-based program that requires a portion of the electric load in Massachusetts be met via eligible technologies.
- Generation Unit owners receive an incentive by selling Alternative Energy Certificates (AECs), which they accrue based on their energy generation, to entities in Massachusetts with a compliance obligation
- Project receive AECs, based on their metered production, on a quarterly basis.
- Typically through an aggregator, system owners can sell AECs generated by their system in the market to receive a monetary incentive
- Please note while utilizing ground source heat pumps for cooling is allowed, only the Useful Thermal Energy used for heating is eligible to generate AECs
- Any ground source heat pump installed in a building shall be eligible for an additional multiplier of 2 (added to the base multiplier) if the building meets the Department of Energy definition of “Zero Energy”




Source:


<https://www.mass.gov/service-details/qualifying-ground-source-heat-pump-in-the-aps>

# HVAC Air-Handling Unit Diagram 1


## ROOF MOUNTED AIR HANDLING UNIT - MIXED AIR DISPLACEMENT VENTILATION SYSTEM w/ UV-C




## HVAC Air-Handling Unit Diagram 2



PLAN VIEW



LEFT DECK ELEVATION VIEW



RIGHT DECK ELEVATION VIEW

## Component Key

(A)	Access Section				Supply Fan		
	Left Door (WxH):	16 ins x 66 ins			Fan Type:	Centrifugal - Plenum	
(B)	Plenum Section				Fan Size (Class):	18 (2)	
(C)	Plenum Section				Air Flowrate:	5900.0 cfm	
	Right Door (WxH):	24 ins x 66 ins		(R)	T.S.P.:	5.9 insWg	
	Panel Filter				Motor Power:	15.0 HP	
(D)	Filter Type:	Pleated (MERV 8)			Control box door swing:	9.10 ins	
	Right Door (WxH):	8 ins x 70 ins			Right Door (WxH):	24 ins x 66 ins	
(E)	Access Section				Plenum Section		
	Right Door (WxH):	8 ins x 66 ins		(S)	Opening Location:	Bottom	
	Energy Recovery Wheel				Opening Size:	24 ins x 38 ins	
	Model:	ECW 606			Right Door (WxH):	20 ins x 66 ins	
(F)	Winter Capacity:	387111.6 Btu/hr			Opening dimensions shown are for unit only, refer to curb drawing for duct opening dimensions.		
	Summer Capacity:	145129.6 Btu/hr					
	Right Door (WxH):	18 ins x 36 ins					
	Left Door (WxH):	18 ins x 36 ins					
(G)	Top Recirc Section						
	Left Door (WxH):	20 ins x 66 ins					
(H)	Bottom Recirc Section						
	Right Door (WxH):	20 ins x 66 ins					
(I)	Access Section						
	Left Door (WxH):	26 ins x 66 ins					
(J)	Access Section						
	Left Door (WxH):	26 ins x 66 ins					
	Panel Filter						
(K)	Filter Type:	Pleated (MERV 8)					
	Left Door (WxH):	8 ins x 70 ins					
	Plenum Section						
(L)	Opening Location:	Bottom					
	Opening Size:	24 ins x 38 ins					
	Left Door (WxH):	24 ins x 66 ins					
(M)	Access Section						
	Return Fan						
	Fan Type:	Centrifugal - Plenum					
(N)	Fan Size (Class):	18 (2)					
	Air Flowrate:	5900.0 cfm					
	T.S.P.:	2.4 insWg					
	Motor Power:	7.5 HP					
	Control box door swing:	9.10 ins					
	Left Door (WxH):	22 ins x 66 ins					
	Panel and Cartridge Filter						
(O)	Pre Filter Type:	Pleated (MERV 8)					
	Cartridge Filter Type:	Varicel SH					
	Right Door (WxH):	18 ins x 70 ins					
	Combination Coil						
	Heating Coil Type:	Hot Water					
	Heating Model:	5WH1402C					
(P)	Cooling Coil Type:	Cold Water					
	Cooling Model:	5WL0810A					
	Cooling Total Capacity:	264333.0 Btu/hr					
	Heating Total Capacity:	231037.0 Btu/hr					
	Right Door (WxH):	16 ins x 60 ins					
(Q)	Access Section						
	Right Door (WxH):	20 ins x 66 ins					



# MERV-14 VS. MERV-16 FILTRATION

Option	Description	Annual Elec. Cons. (kWh)	Combined Utility Cost	Annual Utility \$/s.f.	Annual kBTU/s.f. (EUI)	Combined Expense Savings*	Energy Cost Savings Percentage
Tier 2 Design Building	1. Design Envelope (Wall Insulation R-24 c.i., Roof Insulation R-60 c.i., Curtainwall/Windows 0.35 U-Value/0.40 SHGC, Skylights 0.25 U-Value/0.40 SHGC) 2. Design Mechanical Systems <u>w/ MERV-14 Filters</u> (Refer to Tier 2 Option) 3. Design High-Efficiency Lighting System (0.45 w/s.f.) 4. Electric Domestic Hot Water Systems	693,790	\$138,757	\$1.23	20.92	\$91,688	39.8%
Option	Description	Annual Elec. Cons. (kWh)	Combined Utility Cost	Annual Utility \$/s.f.	Annual kBTU/s.f. (EUI)	Combined Expense Savings*	Energy Cost Savings Percentage
Tier 2 Design Building	1. Design Envelope (Wall Insulation R-24 c.i., Roof Insulation R-60 c.i., Curtainwall/Windows 0.35 U-Value/0.40 SHGC, Skylights 0.25 U-Value/0.40 SHGC) 2. Design Mechanical Systems <u>w/ MERV-16 Filters</u> (Refer to Tier 2 Option) 3. Design High-Efficiency Lighting System (0.45 w/s.f.) 4. Electric Domestic Hot Water Systems	701,000	\$140,199	\$1.24	21.14	\$93,043	39.9%







# HVAC System – UV-C technology

## Potential addition of UV-C system to RTUs

### Benefits:

- UV-C has very short wavelengths and is therefore extremely energetic.
- UV-C, aka Germicidal UV, de-activates microorganism DNA/RNA to stop reproduction.
- UV-C system when placed near cooling coils will continuously clean coils, helping to maintain efficiency. Reduces coil cleaning costs.
- Minimum fan energy pressure drop penalty
- Can be unit or duct mounted
- Proven Technology
- Approximate 90%+ kill rate effectiveness when used with high efficiency filter and typical design ventilation airflow rates (CO2 demand controls should be over-ridden)
- Industry Test Data available (ASHRAE Standard 185.1)
- Use with High efficiency filter increases effectiveness (MERV-13 minimum, MERV-14 (preferred by ASHRAE))



# HVAC System – UV-C technology

## Potential addition of UV-C system to RTUs

### Cons:

- Additional maintenance costs
- Additional precautions must be taken by maintenance staff to avoid exposure to UV-C and Mercury vapor located in emitters
- Under normal operation UV-C system will not expose occupants to UV-C, Mercury vapors or Ozone; However equipment must be properly maintained to ensure safe operation.
- Not all manufacturers are equivalent in terms of technology and efficiency

### Costs:

- First Cost = Approximately \$0.70 / SF Installed
- Maintenance Cost = Approximately \$0.10 / SF for emitter inspection/changes (Emitters last 9000 hours)
- Energy Costs = negligible increase energy cost

